

CTL DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
IEC 60598-2-22 All editions	General	DSH 0968	2017
Category			
LITE			
Subject	Keywords	Developed by	Approved at
Alternative batteries	<ul style="list-style-type: none"> - Battery - Every type - Electrical characteristics 	ETF5-OSM/LUM	2018 CTL Plenary Meeting
Question			
<p>Often it is necessary to test an emergency lighting luminaire with several alternative batteries. In view of the fact that all batteries have the same electrical characteristics, would it be necessary to repeat the endurance test and luminous flux measurement with every battery?</p>			
Decision			
<p>Every type of battery has to be tested.</p>			
Explanatory notes			
