

CTL DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
IEC/EN 61558-1 All editions	14.2	DSH 1020	2017
Category			
SAFE			
Subject	Keywords	Developed by	Approved at
Temperature of supports for transformers IP 00	<ul style="list-style-type: none"> - Temperature of supports - IP 00 - TRF 	ETF5-OSM/LUM	2018 CTL Plenary Meeting
Question			
<p>Note 1 of clause 14.2 states: “ In the case of transformers with a protection index IP00, the temperature of the support is measured, but the values given in Tables 1 and 3 are not considered”.</p> <p>Does this mean that the temperature of the support must always be given in the TRF as an informative value?</p>			
Decision			
Yes.			
Explanatory notes			
