


CTL DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
IEC 60730-1:2013/ AMD1:2015	6.8.3.4	DSH 2144	2019
Category			
CONT			
Subject	Keywords	Developed by	To be approved
Marking of independently mounted controls to be installed in wiring boxes	Class II Independently mounted control	ETF 4	2020 CTL Plenary Meeting
Question			
<p>Shall an independently mounted control without means of connection to earth and intended to be installed in a wiring box (see examples as shown in the below pictures) be marked with the class II symbol, if it complies with all relevant requirements for protection against electric shock after proper mounting of the control in the wiring box?</p>			
			
Decision			
As the control itself does not fulfil all requirements for class II, but only after proper mounting in a wiring box, the control shall not be marked with the class II symbol.			
Explanatory notes			
N/A			